

SOLD AMBASSADOR STEEL CORP
 PO BOX 2340
 TO: KOKOMO, IN 46904-2340

NUCOR
NUCOR STEEL KANKAKEE, INC.

CERTIFIED MILL TEST REPORT

SHIP AMBASSADOR STEEL CORP-CUST TRK
 CUST TRUCK
 TO: KOKOMO, IN 00000-

Ship from:
 Nucor Steel Kankakee, Inc.
 One Nucor Way
 Bourbonnais, IL 60914
 815-937-3131

Date: 11-Aug-2010
 B.L. Number: 412268
 Load Number: 5691290

Material Safety Data Sheets are available at www.nucorbar.com or by contacting your inside sales representative.

NBMG-08 March 24, 2009

HEAT NUM. *	DESCRIPTION	PHYSICAL TESTS					CHEMICAL TESTS													
		YIELD P.S.I.	TENSILE P.S.I.	ELONG % IN 8"	BEND	WT% DEF	C	NI	Mn	Cr	P	Mo	S	V	SI	CB	Cu	Sn	C.E.	
PO# =>	0000091290																			
KN1010344601	Nucor Steel - Kankakee Inc 16/#5 Rebar 20' A615M Gr 420 (Gr60) ASTM A615/A615M-09b GR 60[420] AASHTO M31-07	67,657	101,842	11.3%	OK	-2.9%	.35	.22	.13	.92	.013	.073	.044	.012	.21	.001	.38	.53		
PO# =>	0000091290																			
KN1010344701	Nucor Steel - Kankakee Inc 16/#5 Rebar 20' A615M Gr 420 (Gr60) ASTM A615/A615M-09b GR 60[420] AASHTO M31-07	70,362	103,860	15.0%	OK	-2.4%	.36	.23	.14	.99	.015	.078	.044	.012	.21	.001	.37	.56		
PO# =>	0000091290																			
KN1010345401	Nucor Steel - Kankakee Inc 16/#5 Rebar 20' A615M Gr 420 (Gr60) ASTM A615/A615M-09b GR 60[420] AASHTO M31-07	70,171	106,153	12.5%	OK	-1.0%	.39	.24	.09	.94	.013	.080	.044	.013	.22	.001	.40	.57		
PO# =>	0000091290																			
KN1010345401	Nucor Steel - Kankakee Inc 16/#5 Rebar 20' A615M Gr 420 (Gr60) ASTM A615/A615M-09b GR 60[420] AASHTO M31-07	484MPa	732MPa																	

I HEREBY CERTIFY THAT THE ABOVE FIGURES ARE CORRECT AS CONTAINED IN THE RECORDS OF THE CORPORATION.

ALL MANUFACTURING PROCESSES OF THE STEEL MATERIALS IN THIS PRODUCT, INCLUDING MELTING, HAVE OCCURRED WITHIN THE UNITED STATES. ALL PRODUCTS PRODUCED ARE WELD FREE. MERCURY, IN ANY FORM, HAS NOT BEEN USED IN THE PRODUCTION OR TESTING OF THIS MATERIAL.

QUALITY ASSURANCE: Curtis Glenn

